

PUBLIC NOTICE NO. MT-06-32  
January 12, 2007

PURPOSE OF PUBLIC NOTICE

The purpose of this notice is to state the Department's intention to issue a wastewater discharge permit to the facility listed in this notice. This permit is issued by the Department under the authority of 75-5-402, Montana Code Annotated (MCA); the Administrative Rules of Montana (ARM) 17.30.1301 et seq., Montana Pollutant Discharge Elimination System (MPDES); and Sections 402 and 303 of the Federal Clean Water Act. The Water Protection Bureau has prepared a draft permit for the facility listed below. Copies of the draft permit, statement of basis, and environmental assessment are available upon request from the Water Protection Bureau or on the Department's website [www.deq.mt.gov](http://www.deq.mt.gov).

APPLICANT INFORMATION

APPLICANT:	City of Fort Benton P.O. Box 8 Fort Benton, MT 59442
FACILITY NAME:	City of Fort Benton Wastewater Treatment Facility
FACILITY LOCATION:	T 24N, R 8E, Section 24, Chouteau County
RECEIVING WATER:	Outfall 001: Missouri River Outfall 002: Infiltration pond
PERMIT NUMBER:	MT0021601

This permit is a reissuance of a Montana Pollutant Discharge Elimination System (MPDES) permit for a domestic sewage treatment facility. The permittee operates a three-cell lagoon facility for treatment of domestic wastewater. Discharge is continuous. The facility is not equipped for disinfection. The permittee discharges to either the Missouri River (Outfall 001) or to an infiltration pond (Outfall 002).

On September 21, 2000, a U.S. District Judge issued an order stating that until all necessary

total maximum daily loads under Section 303(d) of the Clean Water Act are established for a particular water quality limited segment, the State is not to issue any new permits or increase permitted discharges under the MPDES program. The order was issued in the lawsuit Friends of the Wild Swan v. U.S. EPA, et al., CA 97-35-M-DWM, District of Montana, Missoula Division. The DEQ finds that the issuance of this proposed permit does not conflict with the order because the discharge is not a new or increased source.

### PUBLIC COMMENT

Public comments are invited ANYTIME PRIOR TO CLOSE OF BUSINESS February 13, 2007. Comments may be directed to the DEQ Permitting & Compliance Division, Water Protection Bureau, PO Box 200901, Helena, MT 59620. All comments received or postmarked PRIOR TO CLOSE OF BUSINESS February 13, 2007 will be considered in the formulation of final determinations to be imposed on the permits. If you wish to comment electronically, you may e-mail Dianne McKittrick at [WPBPublicNotices@mt.gov](mailto:WPBPublicNotices@mt.gov).

During the public comment period provided by the notice, the Department will accept requests for a public hearing. A request for a public hearing must be in writing and must state the nature of the issue proposed to be raised in the hearing (ARM 17.30.1373).

The Department will respond to all substantive comments and issue a final decision within sixty days of this notice or as soon as possible thereafter. Additional information may be obtained upon request by calling (406) 444-3080 or by writing to the aforementioned address. The complete administrative record, including permit application and other pertinent information, is maintained at the Water Protection Bureau office in Helena and is available for review during business hours.

PUBLIC NOTICE NO. MT-06-32

January 12, 2007